

VOC Content Test Certificate

Thursday, 8th March 2018

Supplier: Moggens NZ Ltd (31 Agapanthus Place, Dannemora, Auckland, 2016, New Zealand)

Sample Description: Staerk Multipurpose Fill All Gap

Date Tested: March 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B	Staerk Multipurpose Fill All Gap
General Purpose Adhesives and Sealants: 50 grams per Litre as VOC content per material	30 grams per Litre as VOC content
<p><i>We hereby certify that Staerk Multipurpose Fill All Gap is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV180311